

TU TECHNOLOGY CONSTRUCTORS INCORPORATED

5636 Kendall Court, Unit A
Arvada, Colorado 80002-2747

Phone: (303) 431-2961 Fax: (303) 431-0091

Date: 11/04/08
To: City of Greenwood Village
10001 East Costilla Ave.
Greenwood Village, CO 80112-3730



Public Works/Engineering

- Approved, no exception taken
- Approved, as noted
- Not approved, Resubmit.

Approval of the shop drawings and/or submittals shall not relieve the contractor of their obligations under the requirements of the Contract and shall not relieve the Contractor of the responsibility for the accuracy of the shop drawings. Change to the approved shop drawings and/or submittals requires reapproval.

11/5/08 Attention: Carmen Harrington
Date Signature

JOB NO.: 110004
Job Name: City Hall Patio Replacement
Project

We are sending you:

Shop drawings _____ Prints _____ Plans _____
Specifications _____ Samples _____ X Other _____ Submittals _____

Enclosed is the following:

# OF COPIES	
1	No. 57 Aggregate - G Rock #56 C-33 (Albert Frei & Sons)
1	Base Course Aggregate - G Rock #56 C-33 (Albert Frei & Sons)
1	Sub-Base Course Aggregate - No. 2 Stone, Pit 6 (Albert Frei & Sons)

These are transmitted as checked below:

For approval _____ X For your use _____ X As requested _____
Per contract _____ Approved as noted _____ Approved as submitted _____
Returned for corrections and resubmit _____ Other _____

Remarks:

Copies to:

File _____

Signed: [Signature]
Ed Callejo, Estimator/Project Manager

D:\TRANSMIT.XLS
REV 6/00

If enclosures are not as noted, kindly notify us at once.

4.) Still need Bedding Course submission

- Notes:
- 1.) No 57 aggregate approved in lieu of No. 53 aggregate
 - 2.) Base Course: G Rock #56 C-33 Approved for Base Course
 - 3.) Sub-Base Course: No. 2 Stone Pit 6 Approved for Sub-Base Course